



DATE: July 22, 2019

FROM: Wight & Company
2500 N. Frontage Road
Darien, IL 60561

SUBJECT: ADDENDUM #3 TO THE BIDDING DOCUMENTS FOR:
BID GROUP #7
MASTER FACILITY PLAN IMPLEMENTATION
COMMUNITY HIGH SCHOOL DISTRICT 99
1436 NORFOLK STREET
DOWNERS GROVE, IL 60516

Wight & Company
wightco.com
.....
2500 North Frontage Road
Darien, IL 60561
.....
P 630.969.7000
F 630.969.7979

This addendum forms a part of the Bidding Contract Documents, dated June 7, 2019. Bidders must acknowledge receipt of this Addendum in the space provided on the Bid Form. Drawing revisions clouded and tagged with delta 30.

SOUTH

I. Clarifications

QUESTION: Interior elevations 1 and 2 on A7.12 show frames labeled as "new hollow metal window, typ." Wall section 2 on A5.01 show these as "existing window to remain." Please clarify if these are new or existing to remain.

ANSWER: Elevations 1 & 2 on A7.12 have no new hollow metal windows. The only new hollow metal windows required are level 2, visible in elevation 3/A7.12. Wall section 2/A5.01 applies for the walls visible in elevations 1 & 2 on A7.12. There is a total quantity of 12 new hollow metal windows, type A, required for this wall

II. Specifications

None

III. Modified Drawings

None

END OF ADDENDUM