



**Date:** November 2 2022

**Subject:** ADDENDUM #5

**From:** Wight & Company

**Project:** Transition Building  
(T99) Addition

**Project No:** 220082

This addendum forms a part of the Bidding Contract Documents, dated October 17, 2022. Bidders must acknowledge receipt of this Addendum in the space provided on the Bid Form. Revisions are clouded and tagged throughout the drawings with Delta 2.

**Attached:**  
**Question and Answer Log**

END OF ADDENDUM #5



**Project Name:** Community District 99 Transition Building Addition

**Project Number:** 220082

**Date:** November 2<sup>nd</sup>, 2022

## Bid Question/Answer Log No. 3

The following clarification information is provided in response to questions received in accordance with the bid documents for the following Bid Packages:

Bid Group: 1  
 Bid Packages: 1-23

#	Questions	Date	Answers	Date/By
1.	Please clarify glass makeup for Door Marks FG, N, Frame Types S1 & S2 on page A8.00.	11/2/22	5/16" Laminated glass clear.	11/2/22 DA
2.	BP 6 Glazing scope of work calls out cleaning of Metal Framed Skylights. Skylights are not called out on the plans or anywhere else in our scope. Please clarify we should disregard this note.	11/2/22	This was a misprint and left over from the previous project. Please disregard. Please note you do owe cleaning of all glazing that you install.	11/2/22 NS
3.	The spec on WDC-1 asks for "Create! Wood Looks Ultima High NRC, Beveled Tegular"... but per Armstrong, The create! Wood looks ultima is ONLY square edge, and they cannot do High NRC, it would just be standard Ultima.  An alternate option would be Lyra PB wood looks, which could have a revealed edge. Please advise on how to figure this for the sealed bid.	11/2/22	WDC-1 = ARMSTRONG LYRA PB WOOD LOOK SQUARE TEGULAR 15/16", 24" X 60" TILES, COLOR EARL GREY TEAK (WGT)  Please switch WDC-1 to product above.	11/2/22 AT